


2576


G-000-103.27

**WASTEWATER TREATMENT PLANT SELF-
MONITORING REPORT VIOLATIONS FO
AUGUST, 1991 NPDES PERMIT NO. 11000004*CD
OH0009580**

11/08/91

OEPA/DOE-FO

1

LETTER



State of Ohio Environmental Protection Agency

Southwest District Office

40 South Main Street
Dayton, Ohio 45402-2086
(513) 285-6357
FAX (513) 285-6249

George V. Voinovich
Governor

2576

November 8, 1991

Re: WASTEWATER TREATMENT PLANT
SELF-MONITORING REPORT
VIOLATIONS
FOR AUGUST, 1991
NPDES PERMIT NO. 11000004*CD
OH0009580

Department of Energy
FEMP
P.O. Box 398705
Fernald, Ohio 45239-8705

ATTN: Mr. Robert E. Tiller, Manager

Gentlemen:

We have received your self-monitoring report covering the month of August, 1990, for the referenced facility. Our review indicates a violation of the conditions of your NPDES permit. The specific instance of noncompliance was as follows:

EFFLUENT LIMIT VIOLATIONS

<u>Parameter</u>	<u>Code</u>	<u>Permit Limitation</u>	<u>Reported</u>
Nickel	01067	165 ug/l (day max.)	166 ug/l

Please be advised that failure to comply with the effluent limitations of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reason for the above violation and the action being taken to prevent further occurrences. No additional information is requested at this time.

If you have any questions regarding the above, please contact me at this office.

Sincerely,


David M. Okerbloom
District Representative

DMO/acn

cc: DWPC, Enforcement and Compliance Section

NOV 13 1991

F-0607

1